

## Yoga Installation - Infratech Heaters

Install according to the [Customer and Contractor Checklist - Installation/Operation](#)

Here are the manual and clearances which are dictated in the linked literature.

- [W-Series Manual \(W&WD\)](#)
- 4,000 Watts
- Optimal height: 10-11' AFF
- Clearance from ceiling: 6"
- Clearance from adjacent walls: 18"
- Sprinkler clearance: 6'
- Clearance from fixtures: 3' in front, 18" on sides
- Clearance from Add'l heaters: 3'

Here are our infrared hot yoga support guides. More information can be found on our [Support Hub](#):

- [Ecobee Wiring Diagrams](#)
- [Infrared Yoga Installation Guide](#)
- [Heating Green Infrared Yoga Operation Guide](#)

If your electrician has any questions about wiring the controls (thermostat, relays, transformer) they can reach out directly to the [Professional Technical Support Line at Jackson Systems 1-888-652-9663](#). They are available 8 AM - 6 PM EST M-F.

Relays: Each relay should have its own dedicated circuit and control a group of heaters

- The total amperage of the panels (wattage/volts= amps) should not exceed 80% of the amperage of the relays (ex: 30 amp relays should not exceed 24 amps in regards to the number of heaters)
- We recommend placing relays in an accessible area such as near the electrical panel

